

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 6200-1512:101 Page 1 of 1

**CATEGORY:** Exit Signs

**LISTEE:** SRB Technologies, Inc., 2580 Landmark Drive, Winston-Salem, NC 27103  
Contact: \*Jim Roberts (336) 659-2610 Fax (336) 768-7720

**DESIGN:** Model 171, Betalux-E series, self-luminous exit sign, followed by -R, -GN or -BK, followed by -U, followed by -10, -15 or -20, followed by -S or -D, with or without -PW, -PM, -AF, -CSEBK, -WH, -IF, -RM or -WG. Units illuminate a legally required integral "EXIT" legend, using glass tubes filled with tritium gas to form the legend and directional indicators. Refer to listee's data sheet for additional detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as self-luminous exit signs for use where permitted per code. Authority having jurisdiction should be consulted prior to installation.

\*Rev. 06-12-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 17, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager